

ILLINOIS ARMY NATIONAL GUARD
COMPANY B (MAINT) 634TH FORWARD SUPPORT BATTALION
109 EAST PARK STREET
CHAMPAIGN, ILLINOIS 61820-3720

B-634FSB-66

1 November 2001

MEMORANDUM FOR: See Distribution

SUBJECT: Energy Reduction Program, Champaign Armory

1. Reference:

a. DMAIL Reg 11-28

b. DMAIL Pam 11-28


2. Offices and similar areas shall be heated to no more than 68° F.

3. Low use areas such as drill floors, storage rooms, shops, garages, and other building where employees work in a standing position shall not be heated above 55° F, except during periods of extreme cold where freezing may occur.

4. Offices and work areas shall not be cooled below 75° F.

5. Low use areas will not be air-conditioned unless equipment specifically requires environmental control.

6. Persons employed in Armory and National Guard facilities will use and follow the above references.




TRENT M. SEED
CPT, QM, ILARNG
Commanding

DISTRIBUTION:
Each Individual